



PT Sarana Karyaputra Mandiri
Eightyeighth@Kasablanka Office Tower, 30th Floor, Unit F
Jl. Casablanka Kav. 88, Jakarta Selatan 12870 - Indonesia
Telp. (021) 296 26 094 ; (021) 296 26 096 ; Fax (021) 296 26 095
website : sarakaryaputra.com

ELECTRO KATADYNE

MAKING WATER DRINKING WATER



Laporan General Checkup Unit Katadyne EK-6/24LC Analog

TIV Solok

WT HOD

Aang Irawan

12-13 Juli 2026



PT Sarana Karyaputera Mandiri
Eightyeigh@Kasablanka Office Tower, 30th Floor, Unit F
Jl. Casablanka Kav. 88, Jakarta Selatan 12870 - Indonesia
Telp. (021) 296 26 094 ; (021) 296 26 096 ; Fax (021) 296 26 095
website : saranakaryaputera.com

Summary of Technician's Field Visit

Plant : TIV Solok
Line : WT Line HOD
Technicians : Aang Irawan
PIC Plant : Bapak Maidodi

Maintenance				
Date	Issue	Descriptn	Action Plan	Remark
12 Juli 2026	Pengecekan Unit Katadyn 1	General Checkup Katadyn Analog 600 mA	1. Name Plate unit  2 . Unit Katadyn	No seri/Serial Number Unit : (nameplate tidak ada)



PT Sarana Karyaputera Mandiri
Eightyeigh@Kasablanka Office Tower, 30th Floor, Unit F
Jl. Casablanka Kav. 88, Jakarta Selatan 12870 - Indonesia
Telp. (021) 296 26 094 ; (021) 296 26 096 ; Fax (021) 296 26 095
website : saranakaryaputera.com



3. Pemeriksaan kabel di control panel Box



Note :
- Pastikan kabel tidak kendur



3. Pengecekan Arus katoda-anoda



Note :

- Pengukuran arus pada katoda-anoda, arus terukur 324 mA



PT Sarana Karyaputera Mandiri
Eightyeighth@Kasablanka Office Tower, 30th Floor, Unit F
Jl. Casablanka Kav. 88, Jakarta Selatan 12870 - Indonesia
Telp. (021) 296 26 094 ; (021) 296 26 096 ; Fax (021) 296 26 095
website : saranakaryaputera.com



4. Training operasional unit



Note :
Melaksanakan training
operasional unit bersama
operator dan teknisi



PT Sarana Karyaputera Mandiri
Eightyeigh@Kasablanka Office Tower, 30th Floor, Unit F
Jl. Casablanka Kav. 88, Jakarta Selatan 12870 - Indonesia
Telp. (021) 296 26 094 ; (021) 296 26 096 ; Fax (021) 296 26 095
website : saranakaryaputera.com



Dilaporkan oleh :

